

NOISE READINGS RELATED TO COMPLAINT AT HAWKSWOOD CONDOS

On June 24, 2014, noise complaints were received from the Hawkswood condominium complex located on the northly bank of the Merrimack River to the west of the existing southbound I-95 Whittier Bridge span in Amesbury. As a result, the Walsh-McCourt design/build team deployed noise monitoring equipment on June 24 and 25. The information below is a summary of the recordings. The allowable nighttime limit is 80 decibels (dB) at sensitive receptors (residences, etc.). No recordings at the Hawkswood complex reached the 80 dB limit.

Date	Time	Location	Activity	Lmax
6/24/2014	6:30 PM	In front of East Side of Hawkswood Condos on River	Rivet Busting at Pier 3	70.2
		Adjacent to Pier 3	Rivet Busting at Pier 3	77.4
	9:00 PM	Adjacent to Pier 3	No chipping, lights and generators only	66.5
		Adjacent to Pier 3	Ironworkers bolting and hammering	73.5
		Adjacent to Pier 3	Compressors and chipping at Pier 3	80.9
	9:45 PM	In front of East Side of Hawkswood Condos on River	Chipping at Pier 3	66.7
		In front of West side of Hawkswood Condos on River	Chipping at Pier 3	62.2
Navigation channel at Whittier Bridge		Chipping at Pier 3	79.3	
6/25/2014	12:00 AM	Hawkswood Condos East Drive	No chipping	52.2
		West side of Whittier Bridge	No chipping	60.5
	12:45 AM	Hawkswood Condos East Drive	Chipping at Pier 3	58.6
		West side of Whittier Bridge	Chipping at Pier 3	72.3
	10:00 AM	Main Street and Hawkswood Condos	Chipping at Pier 3	68.4
	11:00 AM	Adjacent to Pier 3	Chipping at Pier 3	77.7
11:15 AM	In front of East Side of Hawkswood Condos on River	Chipping at Pier 3	67.1	